

46993

Log No. _____
 Permit No. _____
 Basin 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21766

1. OWNER Remo T. Pina ADDRESS AT WELL LOCATION 1100 1/4 Sec 19 T 17 N/S R 20 E 12th St Reno NV
 MAILING ADDRESS _____
 2. LOCATION 1100 1/4 Sec 19 T 17 N/S R 20 E 12th St Reno NV County _____
 PERMIT NO. MO224975 Issued by Water Resources Parcel No. 015-291-07 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SP-1		0	0	
gravel		0	5	5
clayey sand		5	6.5	1.5
very coarse fine sand		6.5	11.5	5
coarse sand		11.5	15	3.5
little clay		15	20	5
fine sand				

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 18.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 Inches To 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>sch 40</u>		

Perforations:
 Type perforation 000
 Size perforation _____
 From 3.5 feet to 18.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 3 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 3 feet to 18.5 feet

9. WATER LEVEL
 Static water level 9.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 2/17 1995
 Date completed 2/17 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Drilling Inc Contractor
 Address 75 Weaver Creek Rd Carson City NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1962
 Signed John G. ...
 By driller performing actual drilling on site or contractor
 Date 2/16/95