WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47023
Permit No.
Basin 087

NOTICE OF INTENT NO. 21665

1. ~~OWNER~~ Consultant: ADVANCED SCIENTIFIC SOLUTIONS
MAILING ADDRESS 3983 So. McCarran Blvd. Ste 201
Reno, Nevada 89502

Owner: Wayne Drilling, Inc.
ADDRESS AT WELL LOCATION 465 Lovitt Lane
Reno, Nevada 89506

2. LOCATION SE ¼ NW ¼ Sec. 26 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. M/O 641 MW-3 (Issued by Water Resources) | 003-084-28 (Parcel No.) | Panter Valley (behind Bonanza Casino on No. Virginia Street) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Hollow stem Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Orange brown sandy clay stiff, moist		0	2	2
Light grey and brown argillic altered andesite, very stiff moist		2	25	23

Date started 3-11-93, 19
Date completed 3-11-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 24.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches	0 Feet	25 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		sch 40	0	24.5
PVC end cap & locking cap, Locking Christy Box				

Perforations:
Type perforation factory sawed slot
Size perforation 0.020 x 1¼ x 3 around
From 4 feet to 24.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2 feet
Placement Method: ☒ Pumped ☐ Poured
Bentonite Seal: 2 to 3 feet
Gravel Packed: ☒ Yes ☐ No
From 3 feet to 25 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 9.84 feet below land surface
Artesian flow G.P.M. not known P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date January 17, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627