

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22853

1. OWNER Dennis Lanski ADDRESS AT WELL LOCATION: _____
 MAILING ADDRESS 11830 Overland _____
Reno, Nevada 89506 _____
 2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 15 T. 21N N/S R. 19 E. Washoe County
 PERMIT NO. 080-383-22 _____
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name Lemmon Valley

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6 Well Deepening LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill with gravel cleaned out making (2 GPM)		165	174	9
Gray Granite		174	181	7
Clay Streak		181	192	11
Green Granite		192	221	29
Fracture (6 GPM)	X	221	223	2
Green Granite		223	249	26
Fracture (4 GPM)	X	249	251	2
Green and Gray Granite		251	265	14

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)
 From To
6 1/8 Inches 165 Feet 265 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	265

Perforations:
 Type perforation Factory Sawn Slot
 Size perforation 3/32 x 3 x 5 around
 From 260 feet to 240 feet
 From 220 feet to 200 feet
 From 180 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal Deepening
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 165 feet to 265 feet

Date started 3/7/95, 19____
 Date completed 3/7/95, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
airlift	12		

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. 12 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractors Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Wayne Drilling Inc.
 by driller performing actual drilling on site or contractor
 Date March 8, 1995