WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47033
Permit No.
Basin 085

NOTICE OF INTENT NO. 25013

1. OWNER JIm Vestal
MAILING ADDRESS 260 Parr Blvd.
Reno, NV 89512

ADDRESS AT WELL LOCATION 2600 Rio Seco Lane
Sparks, NV

2. LOCATION SW ¼ SW ¼ Sec. 20 T. 21 N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-690-05 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG		0	45	
Sand and Clay		45	180	
Brown Volcanic Rock		180	235	
DG & Clay		235	315	
Gray Volcanic Rock		315	383	
Brown Volcanic Rock		383	465	
Red Clay		465	475	
Brown Volcanic Rock		475	513	
Gray Clay		513	520	
Yellow Clay		520	533	
Red Clay & Rock		533	545	
Fracture - Brown Rock		545	560	
Gray Volcanic Rock		560	580	

Date started 2/24, 19 95
Date completed 3/02, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15+	580	

8. WELL CONSTRUCTION
Depth Drilled 580 Feet Depth Cased 580 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	20	Feet
10	Inches	20	Feet	55	Feet
8-5/8	Inches	55	Feet	580	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8"		.188	0	580

Perforations:
Type perforation Factory
Size perforation
From 540 feet to 580 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [ ] Pumped [ ] Poured

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 580 feet

9. WATER LEVEL
Static water level 475 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cool °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Diamond Well Drilling Company (Contractor)
Address 1660 Old Airport Road (Contractor)
Auburn, CA 95602
Nevada contractor's license number issued by the State Contractor's Board 0034841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1495
Signed (By driller performing actual drilling on site or contractor)
Date 3/6/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627