

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29102

1. OWNER Cominco American Res. Inc. ADDRESS AT WELL LOCATION Buckhorn Mine
 MAILING ADDRESS P.O. Box 847
Carlin, NV 89822
 2. LOCATION SE 1/4 SE 1/4 Sec 31 T. 27 @/S R. 49 E. Eureka County
 PERMIT NO. M/O-888A Tract of Land
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Gravel, Clay & Boulders		2	18	16
Clay		18	59	41
DK Grey Rock		59	71	12
Clay		71	85	14
Brown, Grey Rock		85	103	18
Clay		103	116	13
Fractured Grey Rock	X	116	118	2
Dk Grey Rock		118	125	7

Placed 3' Bentonite pellet seal above sand pack

Pumped Bentonite Grout from Bentonite Seal to 10'

Neat cement from 10' to surface
 Set 6X6 steel monument around
 PVC casing +3 1/2'

8. WELL CONSTRUCTION
 Depth Drilled 125 Feet Depth Cased 125 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 125 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 40 PVC	+3	125

Perforations:
 Type perforation Millslot
 Size perforation .020
 From _____ feet to _____ feet
 From 105 feet to 125 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 10
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 95 feet to 125 feet

Date started 1-24, 19 95
 Date completed 1-25, 19 95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Not enough water to measure		

9. WATER LEVEL
 Static water level N/A feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Hackworth Drilling, Inc. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
 Signed John Craig Davis
 By driller performing actual drilling on site or contractor
 Date 2-13-95