


OFFICE USE ONLY  
 Log No. 43032  
 Permit No. 60139  
 Basin 054  


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27746

1. OWNER Town of Crescent Valley ADDRESS AT WELL LOCATION 1/4 mile north and 2 miles west of Crescent Valley  
 MAILING ADDRESS P.O. Box 211017  
Crescent Valley, NV 89821  
 2. LOCATION NW 1/4 NE 1/4 Sec. 6 T. 29 N. R. 48 E. Eureka County  
 PERMIT NO. W-420-60139 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cobbles-small to large gravel & coarse sand interbedded w/light brown clay type silt. avg. 10% clayey silt		0	217	217
Cobbles, sandy, gravelly, light brown clayey silt.		217	250	33
Cobbles small to large gravel & coarse sand interbedded w/light brown clayey silt. avg. 10% clayey silt.		250	392	142
Sandy, gravelly light brown clayey silt		392	405	13
* replaced by well log # 113657				

8. WELL CONSTRUCTION  
 Depth Drilled 410 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 18 Inches To 0 Feet 410 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	.250	+1	250
10 3/4	28.04	.250	270	280
10 3/4	28.04	.250	310	320
10 3/4	28.04	.250	390	400

Perforations:  
 Type perforation H.D. wire wrap screen  
 Size perforation Stainless - .120 slots  
 From 250 feet to 270 feet  
 From 280 feet to 310 feet  
 From 320 feet to 390 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 86 feet  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 86 feet to 400 feet

Date started Dec. 21, 19 94  
 Date completed Feb. 19, 19 95

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300		8 hrs.

9. WATER LEVEL  
 Static water level 202 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature Not MF Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co Inc. Contractor  
 Address P.O. Box 590 Contractor  
Winnemucca, NV 89446  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713  
 Signed C. E. Gaylor  
 By driller performing actual drilling on site or contractor  
 Date 3-3-95