

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27161

1. OWNER Spring Creek Utilities ADDRESS AT WELL LOCATION House Palace  
MAILING ADDRESS 225 EAST Sp. Cr. Pkwy  
EIKO NV

2. LOCATION N. 1/4 Sec. 32 T. 33 N. R. 57 E. EIKO County  
PERMIT NO. W-424 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
SAND + small gravel	X	5	100	95
SANDY CLAY		100	140	40
SAND + small gravel		140	230	90
SANDY CLAY WITH SAND		230	510	280
LAYERS				
SANDY CLAY		510	680	170
SAND WITH CLAY		680	760	80
LAYERS				
SANDY CLAY		760	230	60

8. WELL CONSTRUCTION  
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)  
From 6 1/2 Inches To 230 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
Type perforation NO CASING  
Size perforation \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 2-23 1995  
Date completed 2-28 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
Static water level 62 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PPA Drilling Contractor  
Address Box 2487 Contractor  
EIKO NV 27801

Nevada contractor's license number issued by the State Contractor's Board 20684  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1783

Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 3-3-95