

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29909

1. OWNER Robert Toombs ADDRESS AT WELL LOCATION 228 Lazy Lane
 MAILING ADDRESS 611 Bullion Rd #76 Elko NV Pleasant Valley
 2. LOCATION NE 1/4 NW 1/4 Sec. 26 T. 33 N/S R. 57 E. Elko County
 PERMIT NO. 23-011-042 Pleasant Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------|--------------|------|-----|------------|
| Gravel | | 0 | 20 | 20 |
| Cement Sandstone | | 20 | 164 | 144 |
| Loose Sandstone | X | 164 | 170 | 6 |
| Clay | | 170 | 192 | 22 |
| Loose Rock | X | 192 | 200 | 8 |

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6</u> | <u>12.92</u> | <u>1.88</u> | <u>+2</u> | <u>200</u> |

Perforations:
 Type perforation slots
 Size perforation 3/16 x 3"
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 52 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 52 feet to 200 feet

9. WATER LEVEL
 Static water level 98 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fertig Drilling Co Contractor
 Address PO Box 525 Contractor
Elko NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shaulc [Signature]
 By driller performing actual drilling on site or contractor
 Date 3-6-95

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. Draw Down (Feet Below Static) Time (Hours)
40 + 4

7. WELL TEST DATA (continued)

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-------------|-------------------------------|--------------|
| <u>40 +</u> | <u>4</u> | |