WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47067
Permit No.
Basin 024

NOTICE OF INTENT NO. 29757

1. OWNER Michael B. Stewart
MAILING ADDRESS P.O. Box 40 Empire, Nev. 89405
ADDRESS AT WELL LOCATION Orient Farms Walker Basin - 25 mi. North of Yerington Nevada

2. LOCATION NW ¼ NE ¼ Sec 11 T. 35N N/S R. 23 E. Washoe County
PERMIT NO. [redacted] 23494 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	15	15
Brn Clay Streaks Sandy + Gravel		15	45	30
Brn Gray Sandy Clay Streaks gravel + Sand		45	150	105
Black Sand + Small gravel	✓	150	190	40
Brn Clay Streaks Sand		190	210	20
Black Sand Streak gravel	✓	210	250	40
Black Sand Streaks Gray Med Fine Sand	✓	250	400	150
Bottom 10 ft Shaley.				

Date started 1-27-95, 19
Date completed 2-23-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
R.P.M. 1700	1500	[redacted] 74 ft	36 hrs

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26	Inches	0	Feet	400	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	0	150 Blank

Perforations:
Type perforation Louise Mill Lower
Size perforation 1/8 Full Flow Screen
From 150 feet to 190 Full Flow feet
From 190 feet to 210 Standard feet
From 210 feet to 250 Full Flow feet
From 250 feet to 400 Standard feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0 to 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 400 feet

9. WATER LEVEL
Static water level 130 ft. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name San Emilio Resources (Contractor)
Address P.O. Box 40 Empire Nev. 89405 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0018705C-23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1558
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-10-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627