WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

PPW-58
STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47078
Permit No.
Basin 061

NOTICE OF INTENT NO. 28565

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ NW ¼ Sec. 19 T. 36 (N) S R. 50 E. EUREKA County
PERMIT NO. 55141 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY & GRAVEL		0	100	100
RED-BROWN CLAY		100		
& GRAVEL			200	100
BROWN CLAY & GRAVEL		200	625	400
RED-BROWN CLAY		625		
WITH SOME ROCK			1,000	375
BROWN CLAY & ROCK		1,000	1,120	120
GRAY CLAY & ROCK		1,120	1,130	10

Date started JANUARY 10, 19 95
Date completed JANUARY 17, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1,130 Feet Depth Cased 1,126 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17	Inches	0	Feet	40	Feet
12¼	Inches	40	Feet	1,130	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	0	40
6	17.02	.250	0	100

Perforations:
Type perforation LOUVERED
Size perforation 3/8"
From 100 feet to 1,126 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 1,130 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 58 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1822
Signed ROD THOMPSON Rod Thompson
By driller performing actual drilling on site or contractor
Date February 22 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627