X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

PPW-34
STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47679
Permit No.
Basin 061

NOTICE OF INTENT NO. 26418

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ SW ¼ Sec. 19 T. 36 (N) S R. 50 E. EUREKA County
PERMIT NO. 55140 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DISPLACED A BENTONITE SLURRY				
WITH AN 80 SECOND				
FUNNEL VISCOSITY FROM				
4000 FT TO 50 FT. FILLED				
TOP 50 FEET OF HOLE WITH A				
16 LB/GAL CEMENT SLURRY				

Date started FEBRUARY 10, 19 95
Date completed FEBRUARY 10, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1,020 Feet Depth Cased 1,000 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	60 Feet
7 7/8 Inches		60 Feet	340 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	24.7	.322	0	60
4	18	SCH 80	0	340

Perforations:
Type perforation SLOT
Size perforation 1/8
From 340 feet to 1000 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 240
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 240 feet to 1,020 feet

9. WATER LEVEL
Static water level FLOWING feet below land surface
Artesian flow 100 G.P.M. 18 P.S.I.
Water temperature 100 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773
Signed M. WAITE Mark Waite
By driller performing actual drilling on site or contractor
Date February 22 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627