PX-92-12

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47084
Permit No.
Basin 061

NOTICE OF INTENT NO. 24286

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ SE ¼ Sec. 19 T. 36 N/X R. 50 E. EUREKA County

PERMIT NO. M/O-441 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DISPLACED 80 SECOND FUNNEL				
VISCOSITY BENTONITE SLURRY				
FROM 800 FT TO 94 FT.				
FILLED HOLE FROM 94 FT				
TO SURFACE WITH 16 LB/GAL				
CEMENT SLURRY				

Date started JANUARY 15, 19 95
Date completed JANUARY 15, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 810 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17 Inches	0 Feet	20 Feet
12 Inches	20 Feet	100 Feet
7 7/8 Inches	100 Feet	810 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	37	.250	0	20
8	22	.250	0	100
4	11	.237	0	800

Perforations:
Type perforation SLOTTED
Size perforation 1/8
From 400 feet to 800 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 320
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 320 feet to 810 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow 35 G.P.M. 150 P.S.I.
Water temperature 70 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773

Signed M. WAITE Mark Waite
By driller performing actual drilling on site or contractor

Date February 22 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627