

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 47087 / 47088
Permit No. _____
Basin. 061
NOTICE OF INTENT NO. 28595

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801
2. LOCATION SW 1/4 SW 1/4 Sec 20 T 36 N 50 E EUREKA County
PERMIT NO. M/O-441A Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL & FILL		0	4	4
CLAY & GRAVEL		4	155	151
VINNINI	20 GPM	155	740	585
LIMESTONE & MUDSTONE	50 GPM	740	860	120
MUDSTONE	120 GPM	860	970	110
MUDSTONE & LIMESTONE	150 GPM	970	1,000	30

8. WELL CONSTRUCTION
Depth Drilled 1,000 Feet Depth Cased 1,000 Feet
HOLE DIAMETER (BIT SIZE)
From To
12 1/4 Inches 0 Feet 19 Feet
7 7/8 Inches 19 Feet 215 Feet
6 1/2 Inches 215 Feet 1,000 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
8 28.5 .322 0 19
6 17 .250 0 215
2 3 SCH 80 0 893
1 1/2 2 SCH 80 0 78
Perforations:
Type perforation DRILLED HOLES
Size perforation 1 1/4 78 feet to 138 feet
From 2 893 feet to 993 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 215 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 1 1/4 64', 2 876' feet to 1 1/4 146', 2 1,000' feet
9. WATER LEVEL
Static water level 1 1/4 138', 2 467' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature _____ °F Quality _____

Date started JANUARY 14 1995
Date completed JANUARY 16 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>5-10</u>		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address 2286 WEST 1500 SOUTH Contractor
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773
Signed MARK WAITE *Mark Waite*
By driller performing actual drilling on site or contractor
Date February 22 1995