PZ-95-1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47087 & 47088
Permit No.
Basin 061

NOTICE OF INTENT NO. 28595

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ SW ¼ Sec. 20 T 36 N/S R 50 E EUREKA County
PERMIT NO. M/O-441A (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL & FILL		0	4	4
CLAY & GRAVEL		4	155	151
VINNINI	20 GPM	155	740	585
LIMESTONE & MUDSTONE	50 GPM	740	860	120
MUDSTONE	120 GPM	860	970	110
MUDSTONE & LIMESTONE	150 GPM	970	1,000	30

'95 FEB 28 A11:59
STATE ENGINEER'S OFFICE

Date started JANUARY 14, 1995
Date completed JANUARY 16, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5-10		

8. WELL CONSTRUCTION
Depth Drilled 1,000 Feet Depth Cased 1,000 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	19 Feet
7 7/8 Inches		19 Feet	215 Feet
6 1/2 Inches		215 Feet	1,000 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	28.5	.322	0	19
6	17	.250	0	215
2	3	SCH 80	0	893
1¼	2	SCH 80	0	78

Perforations:
Type perforation DRILLED HOLES
Size perforation .125
From 1¼" 78 feet to 138 feet
From 2" 893 feet to 993 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 215
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [ ] No
From 1¼"-64', 2"-876' feet to 1¼"-146', 2"-1,000 feet

9. WATER LEVEL
Static water level 1¼"-138', 2"-467' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773

Signed MARK WAITE Mark Waite
By driller performing actual drilling on site or contractor

Date February 22 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627