

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **27875**

1. OWNER Dees Const ADDRESS AT WELL LOCATION 3614 Quail Run Wellington, Nev
MAILING ADDRESS _____
2. LOCATION SE 1/4 SE 1/4 Sec 16 T 10 N/S R 22 E Douglas County
PERMIT NO. 37-630-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay Brown		0	20	20
Gravel + Cobble		20	120	100
saturated	40'			
saturated	*	105	120	15

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet
HOLE DIAMETER (BIT SIZE)
From 9 7/8 Inches To 120 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 5/8 .14 .185 +1 120
Perforations:
Type perforation Factory Milled
Size perforation 3/32
From _____ feet to _____ feet
From 100 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 120 feet

Date started Oct 21 1994
Date completed Oct 24 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1</u>

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling Contractor
Address P.O. Box 1345 Contractor
Dayton, Nev
Nevada contractor's license number issued by the State Contractor's Board 4739A
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1480
Signed Ken A. Enloe
By driller performing actual drilling on site or contractor
Date Oct 25 1994