X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47102
Permit No.
Basin 106

NOTICE OF INTENT NO. 28901

1. OWNER ED MAHONEY
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 3253 REESE GARDNERVILLE

2. LOCATION SE ¼ NW ¼ Sec. 18 T. 10 (N/S) R. 22 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 37-121-26 (Parcel No.) HOLBROOK (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	5	5
Sandy clay w/ Sharp Gravel		5	22	17
Sandy clay		22	27	5
Sandy clay w/ Gravel		27	44	17
Sandy clay		44	50	6
Gravel w/ Sandy clay		50	70	20
Sandy w/ gravel		70	81	11
Gravel w/ Sandy clay		81	87	6
Gravel w/ Some clay		87	95	8
Sandy clay w/ gravel		95	112	17
Gravel w/ Some clay	X	112	124	12
Sandy clay w/ gravel		124	130	6
Gravel w/ Some clay	X	130	138	8
Sandy clay w/ Some Gravel		138	140	2

Date started 2-14, 1995
Date completed 2-17, 1995

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	8	—	3

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	140 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	140

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 3/32
From 120 feet to 140 feet
From T.C. 110 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W. Phillips (By driller performing actual drilling on site or contractor)
Date 2-19-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627