WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47104
Permit No.
Basin 137B

NOTICE OF INTENT NO. 25431

1. OWNER Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480
Round Mountain, Nv. 89045

ADDRESS AT WELL LOCATION
Minesite - Hole #26 AC / MW-102

2. LOCATION NE ¼ SE ¼ Sec. 26 T. 10 N/S R. 43 E. Nye County
PERMIT NO. MO 574 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Plug + Abandon Procedure				
Rig up over well, Run in To bottom w/ 2" Black pipe. Displace well w/ 1500 gal. of water, pumped Thru Tremie pipe.				
Mix in Redi-Mix Truck 130 sks (50% Excess) Cement And 3 sks gel (2%), 71.5 gal. water, (15 PPG).				
Pump into well, bottom To Top., Pull 2" pipe, Refill well w/ Excess Cement, To top of ground.				

RECEIVED NOV 15 '94 AM 11:17 STATE ENGINEER

Date started 10-20, 1994
Date completed 10-20, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	230 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5		Sch. 80	+1	230

Perforations:
Type perforation
Size perforation .102
From 158 feet to 219 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co. (Contractor)
Address 2250 Stowe Dr (Contractor)
Reno, Nv. 89511
Nevada contractor's license number issued by the State Contractor's Board 02457
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Lee Woytek (By driller performing actual drilling on site or contractor)
Date 11-7-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627