WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4710
Permit No. 60412
Basin

NOTICE OF INTENT NO. 13236

1. OWNER MERLE B STEELE
MAILING ADDRESS
ADDRESS AT WELL LOCATION WIGWAM + RUMRILL

2. LOCATION SW ¼ NE ¼ Sec. 16 T. 22 N/S R. 60 E/W CLARK County
PERMIT NO. 60412 (Issued by Water Resources) 178-16-601-013 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + ROCKS		0	5	5
CMT. GRAVEL		5	100	95
LIMESTONE		100	130	30
CMT GRAVEL W/				
STRKS SANDSTONE		130	280	150
SANDSTONE		280	520	240
LIMESTONE W/	660	520	775	255
CMT GRAVEL				

RECEIVED
APR 18 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-7, 1995
Date completed 4-14, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 775 Feet Depth Cased 775 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 3/4 Inches		0 Feet	60 Feet
12 1/4 Inches		60 Feet	775 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	775

Perforations:
Type perforation FACTORY SAW
Size perforation 1/8 x 2 1/2
From 715 feet to 755 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 65
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 65 feet to 775 feet

9. WATER LEVEL
Static water level 605 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER WELL SERVICES (Contractor)
Address 6475 GARY AVE (Contractor)
LAS VEGAS, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 022311
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1966
Signed Pendall Cowee (By driller performing actual drilling on site or contractor)
Date 4-14-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627