

OFFICE USE ONLY  
 Log No. **47130**  
 Permit No. **109**  
 Basin **109**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **24234**

1. OWNER Golden Valley Const. ADDRESS AT WELL LOCATION 219 Tobe Ct Gardnerville NV. 89403  
 MAILING ADDRESS Gardnerville NV. 89403  
 2. LOCATION SW 1/4 SW 1/4 Sec. 3 T. 12 N. 19 E. Douglas County  
 PERMIT NO. 19-501-09 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loose DG Sand		0	2	2
Large Cabbles of Granite		2	40	38
DG Sands (Course)		40	110	70
DG Sands Layers of Clay		110	165	55
Soft Brown Clay		165	183	18
Broken DG Sands fractures of Granite	XX	183	220	37

8. WELL CONSTRUCTION  
 Depth Drilled 220' Feet Depth Cased 220' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 1/4 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 220 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1.188</u>	<u>0</u>	<u>220</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3 x 3/32  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 220 feet

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.H. Pump Company Contractor  
 Address 5551 Hwy 50 E #3 Contractor  
Carson City NV. 89701  
 Nevada contractor's license number 31839  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael Black  
 By driller performing actual drilling on site of contractor  
 Date 1-3-95

Date started 12-29, 1994  
 Date completed 1-3, 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20</u>	<u>60</u>	<u>3 HRS</u>	

'95 JAN -6 P 1:01  
 STATE ENGINEER (000)