

OFFICE USE ONLY  
 Log No. 47133  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27802

1. OWNER Katherine Replogle ADDRESS AT WELL LOCATION 421 Dino CRT  
 MAILING ADDRESS 1513 Hwy 395 N Gard. NV 89410  
 2. LOCATION NW 1/4 SW 1/4 Sec. 23 T. 12 N/S R. 19 E Douglas County  
 PERMIT NO. 19-280-26 Issued by Water Resources Parcel No. none Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	
Boulders		3	17	
DG sand & boulders	↑	17	90	
DG sand		90	97	
DG sand & clay		97	105	
Boulders		105	118	
DG sand & clay	↓	118	225	

8. WELL CONSTRUCTION  
 Depth Drilled 225 Feet Depth Cased 225 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 225 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>7</u>	<u>1.88</u>	<u>0</u>	<u>225</u>

Perforations:  
 Type perforation Factory  
 Size perforation 3 X 5/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 205 feet to 225 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  
 Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 225 feet

9. WATER LEVEL  
 Static water level 37 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

Date started 1/18 1995  
 Date completed 1/13 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air Lift</u>	<u>720</u>		<u>2 HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kowhock Drilling Inc. Contractor  
 Address P.O. Box 1359 Contractor  
Minden, NV 89423  
 Nevada contractor's license number issued by the State Contractor's Board 021268  
 Nevada driller's license number issued by the Division of Water Resources on-site driller 1380  
 Signed Gill Kowhock  
 By driller performing actual drilling on site or contractor  
 Date 1/21/95