

OFFICE USE OF
 Log No. 47135
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27530

1. OWNER BOB EATON ADDRESS AT WELL LOCATION 1938 CATHERINE GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE

2. LOCATION NW 1/4 NE 1/4 Sec. 1 T 12 N R 20 E DOUGLAS County
 PERMIT NO. 23-480-57 WILDFLOWER Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/ GRAVEL		0	15	15
CEMENTED GRAVEL		15	44	29
SANDY CLAY		44	100	56
SANDY CLAY w/ GRAVEL		100	202	102
SANDY CLAY		202	240	38
CLAY, GRAY		240	356	116
SANDY CLAY		356	502	
SAND	✓	502	505	3
SANDY CLAY		505	516	11
SAND	✓	516	522	6
SANDY CLAY		522	533	11
SAND	✓	533	536	3
SANDY CLAY		536	539	3
SAND + GRAVEL	✓	539	545	6
SANDY CLAY		545	549	4
SAND + GRAVEL	✓	549	556	7
CLAY		556	560	4

JAN 23 12:05
 STATE ENGINEERS SEPT 1995

8. WELL CONSTRUCTION
 Depth Drilled 560 Feet Depth Cased 560 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 560 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>560</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 520 feet to 560 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 560 feet

9. WATER LEVEL
 Static water level 1.85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC
 Address 7780 CURRY RD. FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1726
 Division of Water Resources, the on-site driller.
 Signed Paul J. Mooney
 By driller performing actual drilling on site or contractor
 Date 12-29-94

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>5</u>

Date started 12-6, 1994
 Date completed 12-29, 1994