

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **27524**

1. OWNER **IRVIN GESSELMAN** ADDRESS AT WELL LOCATION **715 CUTTER GARDNERVILLE**
MAILING ADDRESS **1645 N. STIMSON AVE LA PUENTE, CA**

2. LOCATION **SW 1/4 NE 1/4 Sec. 24 T. 12 N. R. 20 E. DOUGLAS** County
PERMIT NO. **29-452-28** Parcel No. _____
Issued by Water Resources _____ Subdivision Name **RUHENSTROTH**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	8	8
SAND		8	10	2
SANDY CLAY		10	16	6
SAND		16	24	8
SANDY CLAY		24	41	17
CEMENTED GRAVEL / ROCK'S		41	69	28
SANDY CLAY / GRAVEL'S		69	74	5
SANDY CLAY		74	98	24
SANDY CLAY / GRAVEL'S		98	101	3
SAND / GRAVEL	✓	101	136	35
SANDY CLAY		136	144	8
SAND / GRAVEL	✓	144	180	36

STATE ENGINEERS OF NEVADA
MAR-9 11:18 AM '95

8. WELL CONSTRUCTION
Depth Drilled **180** Feet Depth Cased **180** Feet

HOLE DIAMETER (BIT SIZE)
From **10 5/8** Inches To **0** Feet
From **9 7/8** Inches To **50** Feet
From **50** Inches To **180** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	1.188	+1	180

Perforations:
Type perforation **FACTORY SLOTTED**
Size perforation **3 X 3/32**
From **100** feet to **180** feet

Surface Seal: Yes No Seal Type:
Depth of Seal **50** Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From **50** feet to **180** feet

9. WATER LEVEL
Static water level **75** feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature **COLD** °F Quality **GOOD**

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **EDDCO EXPLORATION, INC**
Contractor
Address **7780 CURRY RD FALCON, NV 89410**
Contractor
Nevada contractor's license number **27673** issued by the State Contractor's Board
Nevada driller's license number **1726** issued by the Division of Water Resources, the on-site driller **1535**
Signed **Pat J. Moore**
By driller performing actual drilling on site or contractor
Date **2/23/95**

Date started **2/20**, 19**95**
Date completed **2/23**, 19**95**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25 +	-	1