


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

OFFICE USE  
 Log No. 47144  
 Permit No. 105  
 Basin 105  


1. OWNER NEVADA JOHNSON ADDRESS AT WELL LOCATION 1872 ARABIAN  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SE 1/4 NW 1/4 Sec. 24 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 29-480-45 Parcel No. 1220-24-201-048 Subdivision Name RUBENSTROTH Lot 1

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	9	9
CEMENTED GRAVEL/BISALT		9	34	25
SANDY CLAY		34	50	16
CEMENTED GRAVEL/BISALT		50	62	12
SAND GRAVEL		62	69	7
CEMENTED GRAVEL		69	80	11
CEMENTED GRAVEL/BISALT		80	82	2
SAND / GRAVEL	✓	122	143	21
SANDY / CLAY / GRAVEL		143	150	7
SAND GRAVEL	✓	150	160	10

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 5/8</u>	0	50		
<u>9 7/8</u>	50	160		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>160</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 140 feet to 160 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

Date started 1-6, 1995  
 Date completed 1-17, 1995

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>1/2 HR</u>

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow - G.P.M. - P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586-T  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-19-95