

47145  
 OFFICE USE ONLY  
 Log No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
 Basin. 105 T  
 18896

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18896

1. OWNER OLSON CONSTRUCTION ADDRESS AT WELL LOCATION 1881 SORREL  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SE 1/4 SW 1/4 Sec. 24 T 12 N R 20 E DOUGLAS County  
 PERMIT NO. 29-480-43 RUHENSTROTH Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	4	4
SANDY CLAY/GRAVEL		4	7	3
SANDY CLAY		7	20	13
CLAY		20	23	3
CEMENTED GRAVEL		23	55	32
SANDY CLAY		55	78	23
CEMENTED GRAVEL		78	107	29
SANDY CLAY		107	118	11
CEMENTED GRAVEL		118	128	10
SAND/GRAVEL		128	137	9
SAND/GRAVEL	✓	137	160	23

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>160</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 75 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV 89406  
 Nevada contractor's license number 27673  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586T  
 Signed [Signature]  
 By drilling performing actual drilling on site or contractor  
 Date 1-3-95

Date started '95 12-27, 1994  
 Date completed 1-2, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>2</u>

95 JAN 23 11:20:05  
 STATE ENGINEERS OFFICE