

Log No. **47147**
Permit No. _____
Basin **107**

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **26581**

1. OWNER **Bob Albanico** ADDRESS AT WELL LOCATION **75 Jessen Smith Valley, NV.**
MAILING ADDRESS **P.O. Box 730 Gardnerville NV. 89410**

2. LOCATION **NW 1/4 NW 1/4 Sec. 35 T. 12 S. R. 23 E. Lyon** County
PERMIT NO. **10-141-12** Parcel No. **Owens** Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **Mud**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	11	11
Sandy clay		11	20	9
Course Sand ^{fine} Sandstone		20	80	60
Course Sand Grey sandy clay		80	160	80
Grey sandy clay		160	240	80
Course Sand	X	240	245	5
Grey sandy clay		245	251	6
Course Sand Small Gravel	XX	251	260	9
Grey sandy clay		260	270	10
Small Gravels	XX	270	282	12
Grey sandy clay		282	284	2
Course Sand Small Gravel	X	284	286	2
Blue clay		286	300	14

8. WELL CONSTRUCTION
Depth Drilled **300** Feet Depth Cased **300** Feet

HOLE DIAMETER (BIT SIZE)
From To
12 3/4 Inches **0** Feet **300** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17	.188	+2	300

Perforations:
Type perforation **Factory slotted**
Size perforation **2 1/2**
From **240** feet to **300** feet

Surface Seal: Yes No Seal Type:
Depth of Seal **100** Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From **100** feet to **300** feet

9. WATER LEVEL
Static water level **42** feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature **cold** °F Quality **good**

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **EDDCO Exploration, INC.** Contractor
Address **7780 Curry Rd. Fallon NV 89406** Contractor
Nevada contractor's license number issued by the State Contractor's Board **27673**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1535**
Signed **Jerald W. Phinnell** By driller performing actual drilling on site or contractor
Date **2-13-95**

Date started **2-7** 19**95**
Date completed **2-13** 19**95**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	100+	—	4