47150

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47150
Permit No.
Basin 163

NOTICE OF INTENT NO. 14609

1. OWNER Vincent & Susan Asay
MAILING ADDRESS
ADDRESS AT WELL LOCATION Peoria & Lava Sandy Valley

2. LOCATION SW ¼ NE ¼ Sec. 26 T. 24S N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 580-240-132 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	1	1
Calichie		1	12	11
Clay		12	17	5
Calichie		17	20	3
Clay		20	27	7
Calichie		27	30	3
Clay		30	44	14
Calichie		44	47	3
Clay		47	62	15
Calichie		62	65	3
Clay		65	72	7
Calichie		72	75	3
Clay		75	81	6
Calichie	WB	81	84	3
Clay		84	91	7
Calichie	WB	91	95	4
Clay		95	102	7
Calichie	WB	102	106	4
Clay		106	119	13
Calichie	WB	119	121	2
Clay		121	128	7
Calichie	WB	128	131	3
Clay		131	137	6
Calichie	WB	137	140	3

Date started 2-27, 1995
Date completed 2-28, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
MAR 21 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation SAW
Size perforation ⅛ inch by 3 inch
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on site or contractor
Date 3-11-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627