

OFFICE USE ONLY
 Log No. 47165
 Permit No. 162
 Basin 162
 NOTICE OF INTENT NO. 14223

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER William Johnson ADDRESS AT WELL LOCATION 4361 W. Retread
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec. 14 T. 20-S N/S R. 52 E Nye County _____
 PERMIT NO. 28-732-10 Parcel No. _____ Subdivision Name Charleston Park Ranchos Unit 3

3. WORK PERFORMED
 New Well Replace Recondition Deepen
 Abandon Other _____

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Gray clay		4	43	39
Brown clay/caliche		43	54	11
Brown clay	X	54	68	14
Gray clay		68	88	20
Gray clay/caliche		88	96	8
Brown clay	X	96	112	16
Gray clay/caliche		112	128	16
Gray clay		128	140	12

RECEIVED
 MAR 02 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
 Type perforation 1/Torch Cut - 1/Factory Cut
 Size perforation 1"width 8"long - 1/8"width 3"long-
 From 100 feet to 140 feet 8 rolls
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Feb. 24, 1995
 Date completed Feb. 24, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>4</u>	<u>1/4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name JIM PIKE WELL DRILLING, LLC Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
 Signed William Johnson
 By driller performing actual drilling on site or contractor
 Date Feb. 24, 1995