WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 49167
Permit No.
Basin 105

NOTICE OF INTENT NO. 27500

1. OWNER S VicTor
MAILING ADDRESS P.O. Box 375
GENOA, NV 89411

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 9 T. 13 N/S R. 19 E Douglas County
PERMIT NO. (Issued by Water Resources) 17-081-26 Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders-Soils		0	20	20
Rock		20	51	31
Fractured Rock		51	108	57
Rock with				
Clay Seams		108	139	31
Gravel And Clay	x	139	140	1
Clay seams				
Fractured Rock		140	173	33
Gravel-Clay	x	173	182	9
Clay-Rock		182	230	48
Clay-Gravel	x	230	231	1
Clay-Rock		231	250	19
				250

Date started Dec. 13, 1994
Date completed Dec. 21, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIRLIFT	11		1
pump	17	30	1.5

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1.5	250

Perforations:
Type perforation mill slot
Size perforation
From 100 feet to 120 feet
From 160 feet to 200 feet
From 220 feet to 240 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Inland Pacific Drilling Co Inc (Contractor)
Address Po Box 831 Yerington NV 89447 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0036582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1958
Signed Joel W Brown (By driller performing actual drilling on site or contractor)
Date December 21, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627