

OFFICE USE ONLY
 Log No. 77171
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 13169

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Donald & Lenore Bemis ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SE 1/4 Sec 36 T 21-S N/S R 53 E Nye County _____
 PERMIT NO. 59910 5 Block 2 Homestead Gardens
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown Clay		4	18	14
Hard Lime		18	30	12
Soft Brown Clay	x	30	128	98
Gypsum Formation with Hard Streaks		128	140	12
Soft Brown Clay / Hard Streaks		140	185	45
Gypsum Formation	x	185	194	9
Brown Clay		194	200	8

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches 0 Feet 200 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18 lbs	.188	0	200

Perforations:
 Type perforation Torch Cut
 Size perforation 1/2 in width 8 in long
 From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started January 7 1995
 Date completed January 11 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>4</u>	<u>1/4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address HCR 77 BOX 36525 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date 2-15-95

RECEIVED
 FEB 28 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

