WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49179
Permit No.
Basin 162

NOTICE OF INTENT NO. 14331

1. OWNER Scott Wright
MAILING ADDRESS
ADDRESS AT WELL LOCATION 751 Irene St.

2. LOCATION NE ¼ NE ¼ Sec. 9 T. 20S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 35-161-07 (Parcel No.) Cal Vegas Ranchos (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	16	10
Calichie		16	18	2
Clay		18	23	5
Calichie		23	25	2
Clay		25	33	8
Calichie		33	36	3
Clay		36	42	6
Calichie		42	47	5
Clay		47	51	4
Calichie	WB	51	58	7
Clay		58	67	9
Calichie	WB	67	69	2
Clay		69	76	7
Calichie	WB	76	78	2
Clay		78	90	12
Calichie	WB	90	93	3
Clay		93	101	8
Calichie	WB	101	106	5
Clay		106	113	7
Calichie	WB	113	115	2
Clay		115	121	6
Calichie	WB	121	128	7
Clay		128	137	9
Calichie	WB	137	140	3

Date started January 13, 1995
Date completed January 17, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
FEB 24 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 8058 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 2/7/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627