WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47182
Permit No.
Basin 162

NOTICE OF INTENT NO. 14338

1. OWNER Merle Roth
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 4 Blagg

2. LOCATION NW ¼ SW ¼ Sec. 34 T. 19S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 29-602-20 (Parcel No.) Gerald Martin Ross (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	2	2
Calichie		2	4	2
Clay		4	19	15
Calichie		19	23	4
Clay		23	36	13
Calichie		36	39	3
Clay		39	46	7
Calichie		46	48	2
Clay		48	50	2
Calichie	WB	50	53	3
Clay		53	62	9
Calichie	WB	62	73	11
Clay		73	79	6
Calichie	WB	79	81	2
Clay		81	99	18
Calichie	WB	99	102	3
Clay		102	111	9
Calichie	WB	111	113	2
Clay		113	126	13
Calichie	WB	126	131	5
Clay		131	137	6
Calichie	WB	137	139	2
		139	140	1

RECEIVED
FEB 24 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started January 20, 1995
Date completed January 24, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12¼	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 8 x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89060
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 2/8/95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627