WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47187
Permit No.
Basin 105

NOTICE OF INTENT NO. 26602

1. OWNER BIFF PLEMEL
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 1519 WILLOW CREEK GARDNERVILLE, NV

2. LOCATION NW ¼ SW ¼ Sec. 35 T 13 (N)S R 20 E DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-540-08 (Parcel No.) WILLOW CREEK (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY W/GRAVEL		0	15	15
CEMENTED GRAVEL		15	45	30
SANDY CLAY W/GRAVEL		45	87	42
SANDY CLAY		87	96	9
SAND + GRAVEL		96	122	26
SANDY CLAY		122	126	4
SAND + GRAVEL	✓	126	130	4
CEMENTED GRAVEL		130	147	17
SAND + GRAVEL	✓	147	170	23

Date started 5-18, 1995
Date completed 5-22, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	1

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
9 7/8	Inches	50	Feet	170	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	170

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 150 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Patrick J. Moore (By driller performing actual drilling on site or contractor)
Date 5-22-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627