

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **27785**

1. OWNER **ART MORAN** ADDRESS AT WELL LOCATION **N/A (E Valley & Drake)**  
MAILING ADDRESS **PO BOX 1842**  
**CARD. NV 89423**  
2. LOCATION **SW 1/4 NE 1/4 Sec. 35 T. 13 N/S R. 20 E Douglas** County  
PERMIT NO. **3119** **23-294-01** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & CLAY		0	20	
SAND & GRAVEL		20	45	
CLAY SAND & GRAVEL		45	75	
GRAVEL & ROCK	X	75	85	
SAND & GRAVEL		85	150	
GRAVEL & ROCK		150	175	
SAND		175	220	
CLAY SAND & GRAVEL		220	265	
CLAY SAND		265	295	
CLAY SAND GRAVEL		295	300	

8. WELL CONSTRUCTION  
Depth Drilled **300** Feet Depth Cased **300** Feet  
HOLE DIAMETER (BIT SIZE)  
From **9 7/8** Inches To **0** Feet **300** Feet  
Inches.....Feet.....Feet  
Inches.....Feet.....Feet  
CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>12.5/165</b>	<b>.188</b>	<b>0</b>	<b>300</b>

Perforations:  
Type perforation **Factory Perf**  
Size perforation **5/32" x 3" x 20"**  
From.....feet to.....feet  
From **300** feet to **200** feet  
From.....feet to.....feet  
From.....feet to.....feet  
From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal **100**  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From **300** feet to **100** feet

9. WATER LEVEL  
Static water level **75** feet below land surface  
Artesian flow.....G.P.M.....P.S.I.  
Water temperature.....°F Quality.....

Date started **9-20**, 19**94**  
Date completed **9-27**, 19**94**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>AIR</b>	<b>120-130</b>	<b>-</b>	<b>4 hrs.</b>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge  
Name **Kawchack Drilling Inc** Contractor  
Address **PO Box 1539 Minden NV 89423** Contractor  
Nevada contractor's license number issued by the State Contractor's Board **#021268**  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **#7495**  
Signed **Michael Allen**  
By driller performing actual drilling on site or contractor  
Date **9-27-94**

WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WEI.J. DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 47189  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

I

NOTICE OF INTENT NO. 27705

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER ART MORAN ADDRESS AT WELL LOCATION N/A (E Valley & Drake)  
 MAILING ADDRESS PO Box 1842  
GARD. NV 89423  
 2. LOCATION SW 1/4 NE 1/4 Sec 35 T 13 N/S R 20 E Douglas County  
 PERMIT NO. 31119 Issued by Water Resources 23-244-01 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & CLAY		0	20	
SAND & GRAVEL		20	43	
CLAY SAND & GRAVEL		43	75	
GRAVEL & SAND	X	75	85	
SAND & GRAVEL		85	150	
GRAVEL & SAND		150	175	
SAND		175	220	
CLAY SAND & GRAVEL		220	265	
CLAY SAND		265	285	
CLAY SAND GRAVEL		285	300	

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 inches To 0 Feet 300 Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.5 lbs</u>	<u>.130</u>	<u>0</u>	<u>300</u>

Perforations:  
 Type perforation Factory Perf  
 Size perforation 5/32" x 3" x 20'  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 300 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 300 feet to 100 feet

9. WATER LEVEL  
 Static water level 75 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kawchack Drilling Inc Contractor  
 Address PO Box 1539 Minden NV 89423 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board #021260  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #495  
 Signed Michael O'Neil  
 Date 9-27-94

Date started 9-20 1994  
 Date completed 9-27 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>AIR 120-130</u>	<u>---</u>	<u>4 hrs.</u>