WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47192
Permit No.
Basin 109

NOTICE OF INTENT NO. 19142

1. OWNER Paul Yeagley
MAILING ADDRESS 8815 Central Ave
Orangvale Calif 85622

ADDRESS AT WELL LOCATION 19 Shirley Lane
Yerington Nev 89447

2. LOCATION SE ¼ SE ¼ Sec. 3 T. 13 N/S R. 26 E. Lyon County
PERMIT NO. 49093 (Issued by Water Resources) 04-342-12 (Parcel No.) #19 South View Sub. Unit #1 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil-Sandy		0	3	3
Coarse Sand-Gravel-Rock		3	30	27
Coarse Sand-Gravel		30	40	10
Sed Fill-Tight		40	58	18
Sed Fill-Clay-Tight		58	113	55
Sed Fill-Rock-Clay		113	130	17
Sed Fill-Rock		130	132	2
Sed Fill-Rock-Clay		132	230	98
Rock-Clay		230	240	10
Clay-Sand-Tight		240	262	22
Clay-Sand-Rock-Tight		262	274	12
Sed Fill-Rock-Tight		274	282	8
Sed Fill-Rock	X	282	290	8
DG Sed Fill	X	290	294	4
Sed Fill-Clay		294	322	28
Fractured Red Granite	X	322	330	8
Clay-Sed Fill		330	350	20
Fractured Red Granite	X	350	357	7

Date started June 29, 1993
Date completed July 15, 1993

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	25	20	½ HRS
Air Lift 200' Line	40		1 HRS

8. WELL CONSTRUCTION
Depth Drilled 357 Feet Depth Cased 358 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10⅝ Inches		0 Feet	86 Feet
9⅞ Inches		86 Feet	357 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	12.92	.188	+1	357

Perforations:
Type perforation Sawed
Size perforation 1/32 x 3" x 6 Rows
From 347 feet to 357 feet
From 322 feet to 332 feet
From 282 feet to 302 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 357 feet

9. WATER LEVEL
Static water level 127 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N By Bee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-23-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627