

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Paul Veagley ADDRESS AT WELL LOCATION 19 Shirley Lane
 MAILING ADDRESS 8815 Central Ave Yerington, Nev. 89442
Orangevale Calif 95622

2. LOCATION SE 1/4 SE 1/4 Sec. 3 T. 13 N. S. R. 26 E. Lyon County _____
 PERMIT NO. 49093 04-342-12 #19 South View Sub Unit #1
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Place Neat Cement FROM BOTTON TO TOP 28 Bags Poured				
Pumped FROM 138' TO TOP No WATER Flow OVER Top				
Very Low yield well - Rusty				

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____
 Inches _____ Feet _____
 Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>-</u>	<u>.156</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to _____ feet

Date started 6-2 1994
 Date completed 6-2 1994

9. WATER LEVEL
 Static water level 131 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Fair

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Bros Drilling Contractor
 Address 162 N ByBee Lane Contractor
Yerington Nev 89447

Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11-22-94