

OFFICE USE ONLY
Log No. 47210
Permit No. _____
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 210821

1. OWNER Keith Winchester ADDRESS AT WELL LOCATION 296 Arrowhead Dr Carson City NV 89701
MAILING ADDRESS 296 Arrowhead Dr Carson City NV 89701
2. LOCATION NE 1/4 NW 1/4 Sec. 6 T. 15 S. R. 20 E Carson County
PERMIT NO. 08-093-05 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft Brown Sands		0	20	20
Sands of Rust/IDA		20	47	27
Dry Brown Clay		47	69	22
Soft coarse Sands		69	96	27
Gummy Clay Seem		96	110	14
Coarse Sands	xxx	110	150	40

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet
HOLE DIAMETER (BIT SIZE)
From 10 1/4 Inches To 150 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>150</u>

Perforations:
Type perforation M.11 slot
Size perforation 3 X 3/32
From 130 feet to 150 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 55
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 55 feet to 150 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow _____ G.P.M. 10 P.S.I.
Water temperature Cold °F Quality Good

Date started 1-9 1995
Date completed 1-13 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>	<u>200</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.H. Pump Company Contractor
Address 555 Hwy 50 E #5 Carson City NV 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1905
Signed W. Richard Beck
By driller performing actual drilling on site or contractor
Date 1-13-95