Silver Oaks-Well #4

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47211
Permit No.
Basin 104

NOTICE OF INTENT NO. 13932

1. OWNER Carson City
MAILING ADDRESS 3300 Butti Way
Bldg #9, Carson City, NV 89710

ADDRESS AT WELL LOCATION 1 1/2 miles west
on Winnie Lane, 1/4 mile north
[redacted]

2. LOCATION NE ¼ NW ¼ Sec. 7 T. 15 (N)S R. 20 E. Carson County
PERMIT NO. 60205T (Issued by Water Resources) | Parcel No. | Silver Oaks (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
See ~~Attached~~ Silver Oaks Test Hole #4 LOG # 47212				

Date started Dec 10, 1994
Date completed Dec 21, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
750	214	24

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
30 Inches	0 Feet	100 Feet
22 Inches	100 Feet	460 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	94.6	.375	0	100
12 1/4	33.36	.250	+2	240
8 5/8	22.36	.250	380	400
8 5/8	22.36	.250	440	450

Perforations:
Type perforation Wire wrap screen
Size perforation .100 slot
From 240 feet to 380 feet
From 400 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 450 feet

9. WATER LEVEL
Static water level 90' 8" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Norm °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P. O. Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed C. C. Eppler (By driller performing actual drilling on site or contractor)
Date 1-27-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627