WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47234
Permit No.
Basin 089

NOTICE OF INTENT NO. 26997

1. OWNER Richard Albrite
MAILING ADDRESS 2410 Harvest Dr
Carson City Nev

ADDRESS AT WELL LOCATION 5559 Franktown Rd
Carson City

2. LOCATION SE ¼ SE ¼ Sec. 15 T. 16 N/S R. 19 E. Washoe County

PERMIT NO. ____ Issued by Water Resources | 55-150-29 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Clay		0	20	20
Rock Clay		20	60	40
Fractured Granite		60	85	25
Fine Sand	*	85	95	10
Fractured Granite	*	95	105	10

'95 JAN 23 P12:17
STATE ENGINEERS OFFICE

Date started Sept 16, 1994
Date completed Sept 23, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr

8. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	105 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	105

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From ____ feet to ____ feet
From 65 feet to 105 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 105 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling
Contractor
Address P.O. Box 1345
Contractor
Dayton, Nev
Nevada contractor's license number issued by the State Contractor's Board 4739 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1757
Signed Troy Enloe
By driller performing actual drilling on site or contractor
Date Sept 26/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627