WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47235
Permit No.
Basin 089

NOTICE OF INTENT NO. 27264

1. OWNER GARY AND MARY, ROMERO
MAILING ADDRESS 4240 PARTRIDGE LANE
CARSON CITY, NV 89704

ADDRESS AT WELL LOCATION
4220 PARTRIDGE
Carson city, NV 89704

2. LOCATION SW ¼ NE ¼ Sec. 5 T 16n N/S R 20E E Washoe County

PERMIT NO. (Issued by Water Resources) | 050-413-38 (Parcel No.) | Washoe Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown sandy with gravels		1	3	2
Brown Sandy Clay		3	8	5
Sand and gravels		8	12	4
Brown sandy Clay with Gravels		12	66	54
Fine Sand		66	67	1
Brown Sandy Clay		67	72	5
Granite Bolder		72	73	1
Brown Clay with Granite Sand		73	135	62
Soft Zone WB		135	155	20
Brown Clay Clay		155	165	10
Gray Sandy Clay		165	170	5

Date started January 30, 1995, 19
Date completed February 1, 1995, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	170 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	170

Perforations:
Type perforation Factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 125 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 88 feet below land surface
Artesian flow G.P.M. 10 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV. 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Edward T. [illegible] (By driller performing actual drilling on site or contractor)

Date Febuary 3. 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627