WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47239
Permit No.
Basin 089

NOTICE OF INTENT NO. 28029

1. OWNER Charles & Sharon Glacken
MAILING ADDRESS 35 Darlyn Ln. Carson City NV. 89706
ADDRESS AT WELL LOCATION 65 Darlyn Ln Carson City NV. 89706

2. LOCATION NW 1/4 NW 1/4 Sec. 31 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. Issued by Water Resources
Parcel No. 50-060-30
Subdivision Name New Washoe City

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	2	2
Rusty Sands		2	12	10
Gray Silty Sands		12	63	51
Gray Gummy Clay Solid Clay Zone		63	91	28
Soft Sands		91	105	14
Fine DG Sands Green White	XXX	105	140	35

Date started 1-28, 1995
Date completed 2-1, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
251	20	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 1/4 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	140

Perforations:
Type perforation Mill Slot
Size perforation 3 X 9/32
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. 251 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Al H Pump Co. (Contractor)
Address 5551 Hwy 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hall
By driller performing actual drilling on site or contractor
Date 2-1-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627