

OFFICE USE
 47244
 Log No. _____
 Permit No. _____
 Basin: 103
 NOTICE OF INTENT NO. 25-206

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Overland Homes ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS #333 Hiway 50 E 191 Territory Rd
Dayton Nev
 2. LOCATION NE 1/4 SW 1/4 Sec. 20 T. 17 N/S R. 21 E Storey County
 PERMIT NO. 03-313-10 Mark Twains Est. Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top soil & cobble</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Cemented gravel & boulders</u>		<u>2</u>	<u>270</u>	<u>268</u>
<u>Saturated consolidated sand & gravel</u>	<u>*</u>	<u>270</u>	<u>320</u>	<u>50</u>

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 320 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 50 Feet
8 3/4 Inches 50 Feet 320 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>320</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 3/32
 From _____ feet to _____ feet
 From 280 feet to 320 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 320 feet

9. WATER LEVEL
 Static water level Apx 270 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enloe Drilling Contractor
 Address P.O. Box 1345 Contractor
Dayton, Nev
 Nevada contractor's license number issued by the State Contractor's Board 14739A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
 Signed Lee A Enloe
 By driller performing actual drilling on site or contractor
 Date Feb 20 1994

Date started Feb 17, 1994
 Date completed Feb 19, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>12</u>		<u>2</u>