

1123 Woodside Drive # 236 (702-888-1417)
Carson City, Nev. 89701

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

Log No. **47246**
Permit No. **103**
Basin **11**
NOTICE OF INTENT NO. **26728**

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Thomas Hall ADDRESS AT WELL LOCATION 119 Julie Way Marktwain
MAILING ADDRESS 119 Julie Way
Duynen NV
2. LOCATION SW 1/4 SE 1/4 Sec. 20 T. 17 N/S R. 22 E. Storey County
PERMIT NO. 03-303-08 Marktwain Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Soil		0	3	3
Bedrock Soil		3	8	5
Bedrock Joints		8	80	72
Red Claystone		80	195	115
Fractured Shell	195	195	256	61
E Clay Shales	256			

95 FEB -2 AM 11:12
STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 256 Feet Depth Cased 257 Feet
HOLE DIAMETER (BIT SIZE)
From To
10 3/8 Inches 1 Feet 60 Feet
7 7/8 Inches 60 Feet 256 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13</u>	<u>1.888</u>	<u>1</u>	<u>256</u>

Perforations:
Type perforation Tool Cst
Size perforation 3/16 x 8 x 4 nozzle perf
From 196 feet to 216 feet
From 236 feet to 256 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 55+ Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 55+ feet to _____ feet

9. WATER LEVEL
Static water level 205 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Reagan Drilling Inc Contractor
Address 20 599 Contractor
33 NV, 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed Daniel Reagan
By driller performing actual drilling on site or contractor
Date 1/25/95

Date started 1/17, 1995
Date completed 1/21/95, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+ gpm</u>		<u>3 3/4 hrs</u>