

47261
 OFFICE USE ONLY

Log No. _____
 Permit No. _____
 Basin. 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22868

1. OWNER KEVIN JEFFERS/TOMAS SORENSEN OWNER ADDRESS AT WELL LOCATION
 MAILING ADDRESS 1055 Riverside Drive 430 Anitra
 Reno, Nevada 89053 Reno, Nevada 89511
 2. LOCATION SW 1/4 SE 1/4 Sec 2 T 18N N/S R 19 E Washoe County
 PERMIT NO. 041-290-25 SW Reno
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Volcanic boulder		1	2	1
Gray volcanic rock		2	18	16
Purple volcanic rock		18	32	14
Brown volcanic rock		32	89	57
Gray volcanic rock		89	148	59
Brown volcanic rock		148	198	50
Fracture rock	X	198	235	37
Hard brown volcanic rock		235	251	16
Fracture rock	X	251	267	16
Brown volcanic rock		267	270	3
Reddish volcanic rock		270	274	4
Brown volcanic rock		274	290	16
Gray volcanic rock		290	318	28
Fracture volcanic rock	X	318	333	15
Gray volcanic rock		333	347	14
Fracture rock	X	347	368	21
Gray volcanic rock		368	400	32

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
 10 Inches 0 Feet 100 Feet
 8 5/8 Inches 100 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	400

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 255 feet to 275 feet
 From 295 feet to 315 feet
 From 335 feet to 355 feet
 From 375 feet to 395 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 400 feet

9. WATER LEVEL
 Static water level 200 feet below land surface
 Artesian flow _____ G.P.M. 35 P.S.I.
 Water temperature cold °F Quality clear

Date started 1-4-95, 19_____
 Date completed 1-9-95, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	35		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
 RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date January 14, 1995