WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 47270
Permit No.
Basin 102

NOTICE OF INTENT NO. 2-60014

1. OWNER David Waldie
MAILING ADDRESS Quincy Street Silver Springs Nevada 89429
ADDRESS AT WELL LOCATION Quincy Street Silver Springs, Nevada 89429

2. LOCATION SE ¼ NW ¼ Sec. 33 T. 18 N/S R. 24 E. Lyon County
PERMIT NO. N/A Issued by Water Resources | 18-473-10 Parcel No. | Ramsey #3 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVD
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	4	4
Gravels with Some tan Clay		4	63	59
Cemented Gravels		63	156	93
Tan Clay		156	206	50
Brown Clay with Some Sand		206	280	74
Cemented Gravels And Sand		280	300	20

Date started 1-25, 19 95
Date completed 1-30, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 2 Hours And produced about 15 Gallons A min.		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
7 7/8 Inches	120 Feet	280 Feet
5 3/4 Inches	280 Feet	300 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	280
5 5/8	11.00	3/16	280	300

Perforations:
Type perforation Torch Cut
Size perforation 1/4 X 16 Long 5 Rows
From [redacted] feet to [redacted] feet
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc Contractor
Address Po Box 599 Contractor
Silver Springs Nv 89429
Nevada contractor's license number issued by the State Contractor's Board C0318(1)
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 1-30-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627