WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47292
Permit No.
Basin 162

NOTICE OF INTENT NO. 14556

1. OWNER Sullivan
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3230 E Wall St

2. LOCATION NW ¼ SW ¼ Sec. 31 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 45-431-21 (Parcel No.) Cal Vista Sub (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	6	6
Calichie		6	9	3
Clay		9	14	5
Calichie		14	16	2
Clay		16	21	5
Calichie		21	25	4
Clay		25	36	11
Calichie		36	38	2
Clay		38	47	9
Calichie		47	51	4
Clay		51	64	13
Calichie		64	66	2
Clay		66	81	19
Calichie		81	84	3
Clay		84	98	14
Calichie	WB	98	101	3
Clay		101	117	18
Calichie	WB	117	122	5
Clay		122	128	8
Calichie	WB	128	131	3
Clay		131	144	13
Calichie	WB	144	146	2
Clay		146	150	4

RECEIVED
MAR 01 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-25, 1995
Date completed 1-28, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	150 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	150

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ x 3
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun
By driller performing actual drilling on site or contractor
Date 3-1-95

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
101-627