WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.440

OFFICE USE ONLY
Log No. 47293
Permit No.
Basin

NOTICE OF INTENT NO. 14665

1. OWNER Terry + Susan Torgerson
MAILING ADDRESS HC 78 Box 70935 Pahrump NV. 89041
ADDRESS AT WELL LOCATION Pahrump Valley Blvd + Carberry Lot 31

2. LOCATION NW ¼ SW ¼ Sec. 2 T. 21 S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-212-10 (Parcel No.) Rancho View Estates (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	12	12
Calichie		12	14	2
Clay		14	23	9
Calichie		23	26	3
Clay		26	35	9
Calichie		35	37	2
Clay		37	53	16
Calichie		53	55	2
Clay		55	59	4
Calichie	W.B	59	63	4
Clay		63	71	8
Calichie	W.B	71	77	6
Clay		77	88	11
Calichie	W.B	88	90	2
Clay		90	104	14
Calichie	W.B	104	106	2
Clay		106	120	14
Calichie	W.B	120	124	4
Clay		124	134	10
Calichie	W.B	134	138	4
Clay		138	140	2

RECEIVED
MAR 07 1995
Div. of Water Resources
Branch Office, Las Vegas, NV

Date started 2-20, 1995
Date completed 2-24, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ inch by 3 inch
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 Pahrump NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 2-24-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627