WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47294
Permit No.
Basin

NOTICE OF INTENT NO. 14664

1. OWNER PAUL + PAM MOORE
MAILING ADDRESS STAR ROUTE 70905
PAHRUMP NV. 89041

ADDRESS AT WELL LOCATION MANSE + RACHEL

2. LOCATION NW ¼ NW ¼ Sec. 12 T 21 S N/S R 53 E NYE County

PERMIT NO. ____ (Issued by Water Resources) | 44-511-24 (Parcel No.) | NA (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	2	2
CALICHIE		2	4	2
CLAY		4	14	10
CALICHIE		14	17	3
CLAY		17	33	16
CALICHIE		33	38	5
CLAY		38	58	20
CALICHIE	W.B	58	61	3
CLAY		61	74	13
CALICHIE	W.B	74	78	4
CLAY		78	89	11
CALICHIE	W.B	89	92	3
CLAY		92	102	10
CALICHIE	W.B	102	106	4
CLAY		106	128	22
CALICHIE	W.B	128	132	4
CLAY		132	135	3
CALICHIE	W.B	135	140	5

RECEIVED
MAR 07 1995
Water Resources
Branch Office - Las Vegas, NV

Date started 2-9, 1995
Date completed 2-24, 1995

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured

Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV. 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573

Signed [signature]
By driller performing actual drilling on site or contractor

Date 2-24-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627