WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47296
Permit No.
Basin
NOTICE OF INTENT NO. 14567

1. OWNER Avco Const.
MAILING ADDRESS
ADDRESS AT WELL LOCATION 6431 Longhorn

2. LOCATION SW ¼ NE ¼ Sec. 16 T. 21S N/S R. 54 E. Nye County
PERMIT NO. (Issued by Water Resources) 43-061-01 (Parcel No.) Cottonwoods (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt & Cobbles		0	3	3
Clay · Cobbles		3	28	25
Clay		28	30	2
Calichie		30	34	4
Clay		34	39	5
Calichie		39	44	5
Clay		44	51	7
Calichie		51	56	5
Clay		56	62	6
Calichie	WB	62	65	3
Clay		65	73	8
Calichie	WB	73	77	4
Clay		77	85	8
Calichie	WB	85	88	3
Clay		88	97	9
Calichie	WB	97	100	3
Clay		100	109	9
Calichie	WB	109	111	2
Clay		111	121	10
Calichie	WB	121	126	5
Clay		126	138	2
Calichie	WB	138	140	2

RECEIVED
MAR 07 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2/20, 1995
Date completed 2/24, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛" x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dam (By driller performing actual drilling on site or contractor)
Date 3/3/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627