WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.34

OFFICE USE ONLY
Log No. 47324
Permit No.
Basin
NOTICE OF INTENT NO. 14565

1. OWNER Robert Siler
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 23 Bruce St.

2. LOCATION NW ¼ NW ¼ Sec. 2 T. 21S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-162-23 (Parcel No.) Gunnebird (Subdivision Name)

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Calichie		3	5	2
Clay		5	8	3
Calichie		8	10	2
Clay		10	14	4
Calichie		14	17	3
Clay		17	25	8
Calichie		25	31	6
Clay		31	44	13
Calichie		44	47	3
Clay		47	50	3
Calichie	WB	50	52	2
Clay		52	56	4
Calichie	WB	56	59	3
Clay		59	72	13
Calichie	WB	72	76	4
Clay		76	87	11
Calichie	WB	87	92	5
Clay		92	100	8
Calichie	WB	100	103	3
Clay		103	119	16
Calichie	WB	119	123	4
Clay		123	130	7
Calichie	WB	130	133	3
Clay		133	140	7

Date started 2-17, 19 95
Date completed 2-23, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw-Down (Feet Below Static)	Time (Hours)

RECEIVED
MAR 21 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ¼ x 3
From 0 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80.358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dr (By driller performing actual drilling on site or contractor)
Date 3-6-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627