WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 47326
Permit No.
Basin 162

NOTICE OF INTENT NO. 14610

1. OWNER Gloria Blake
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1761 W. Blosser Ranch Rd

2. LOCATION NW ¼ SW ¼ Sec. 32 T. 19S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 29-781-25 (Parcel No.) Rancho Del Sol (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	16	10
Calichie		16	20	4
Clay		20	29	9
Calichie		29	32	3
Clay		32	51	19
Calichie	WB	51	53	2
Clay		53	66	13
Calichie	WB	66	68	2
Clay		68	78	10
~~Cla~~ Calichie	WB	78	81	3
Clay		81	94	13
Calichie	WB	94	98	4
Clay		98	109	11
Calichie	WB	109	111	2
Clay		111	116	5
Calichie	WB	116	118	2
Clay		118	128	10
Calichie	WB	128	132	4
Clay		132	137	5
Calichie	WB	137	140	3

Date started February 24, 19 95
Date completed February 27, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
MAR 21 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation ⅛ x 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 3/16/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627